SIEMENS

Data sheet

6EP3330-6SB00-0AY0



LOGO!Power/1AC/24VDC/0.6A

LOGO!POWER 24 V / 0.6 A Stabilized power supply input: 100-240 V AC output: DC 24 V / 0.6 A

Input	
Input	1-phase AC or DC
Rated voltage value Vin rated	100 240 V
Voltage range AC	85 264 V
input voltage	
• at DC	110 300 V
Wide-range input	Yes
Overvoltage resistance	300 V AC for 1 s
Mains buffering	at Vin = 187 V
Mains buffering at lout rated, min.	40 ms; at Vin = 187 V
Rated line frequency 1	50 Hz
Rated line frequency 2	60 Hz
Rated line range	47 63 Hz
input current	
 at rated input voltage 120 V 	0.3 A
 at rated input voltage 230 V 	0.2 A
Switch-on current limiting (+25 °C), max.	20 A
l²t, max.	0.8 A ² ·s
Built-in incoming fuse	internal
Protection in the mains power input (IEC 898)	Recommended miniature circuit breaker: from 6 A characteristic B or from 2 A characteristic C
Output	
Output	Controlled, isolated DC voltage
Rated voltage Vout DC	24 V
 output voltage at output 1 at DC rated value 	24 V
Total tolerance, static ±	3 %
Static mains compensation, approx.	0.1 %
Static load balancing, approx.	0.1 %
Residual ripple peak-peak, max.	200 mV
Residual ripple peak-peak, typ.	30 mV
Spikes peak-peak, max. (bandwidth: 20 MHz)	300 mV
Spikes peak-peak, typ. (bandwidth: 20 MHz)	50 mV
product function output voltage adjustable	No
Status display	Green LED for output voltage OK
On/off behavior	No overshoot of Vout (soft start)
Startup delay, max.	0.5 s
Voltage rise, typ.	100 ms
Rated current value lout rated	0.6 A

Current renge	
Current range	0 0.6 A
Note	+55 +70 °C: Derating 2%/K
supplied active power typical Parallel switching for enhanced performance	14.4 W No
	NU
Efficiency	04.04
Efficiency at Vout rated, lout rated, approx.	81 %
Power loss at Vout rated, lout rated, approx.	3 W
power loss [W] during no-load operation maximum	0.3 W
Closed-loop control	0.00/
Dynamic mains compensation (Vin rated ±15 %), max.	0.2 %
Dynamic load smoothing (lout: 10/90/10 %), Uout ± typ.	2 %
Load step setting time 10 to 90%, typ.	1 ms
Load step setting time 90 to 10%, typ.	1 ms
Protection and monitoring	
Output overvoltage protection	Yes, according to EN 60950-1
Current limitation, typ.	0.8 A
property of the output short-circuit proof	Yes
Short-circuit protection	Constant current characteristic
enduring short circuit current RMS value	0.0.4
maximum	0.8 A
overcurrent overload capability in normal operation Overload/short-circuit indicator	overload capability 150% lout rated typ. 200 ms
overcurrent overload capability when switching on	 150% lout rated typ. 200 ms
Safety	150 % lout rated typ. 200 ms
	Vec
Primary/secondary isolation	Yes
galvanic isolation Protection class	Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178
Degree of protection (EN 60529)	Class II (without protective conductor) IP20
Approvals	11 20
Approvais	
CE mark	Yes
CE mark	Yes
CE mark UL/cUL (CSA) approval	Yes cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)
UL/cUL (CSA) approval Explosion protection	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC
UL/cUL (CSA) approval	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA-
UL/cUL (CSA) approval Explosion protection	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval EMC	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval EMC Emitted interference	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions ambient temperature	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable EN 61000-6-2
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions ambient temperature • during operation — Note • during transport	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable EN 61000-6-2 $-25 \dots +70 \text{ °C}$ with natural convection $-40 \dots +85 \text{ °C}$
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions ambient temperature • during operation — Note • during transport • during storage	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable EN 61000-6-2 $-25 \dots +70 \ ^{\circ}C$ with natural convection $-40 \dots +85 \ ^{\circ}C$ $-40 \dots +85 \ ^{\circ}C$
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions ambient temperature • during operation — Note • during transport • during storage Humidity class according to EN 60721	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable EN 61000-6-2 $-25 \dots +70 \text{ °C}$ with natural convection $-40 \dots +85 \text{ °C}$
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions ambient temperature • during operation — Note • during transport • during storage	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable EN 61000-6-2 $-25 \dots +70 \ ^{\circ}C$ with natural convection $-40 \dots +85 \ ^{\circ}C$ $-40 \dots +85 \ ^{\circ}C$
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval CB approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions ambient temperature • during operation — Note • during transport • during storage Humidity class according to EN 60721 Mechanics Connection technology	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable EN 61000-6-2 $-25 \dots +70 \ ^{\circ}C$ with natural convection $-40 \dots +85 \ ^{\circ}C$ $-40 \dots +85 \ ^{\circ}C$
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions ambient temperature • during operation — Note • during transport • during storage Humidity class according to EN 60721 Mechanics Connection technology Connections	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA-12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable EN 61000-6-2 -25 +70 °C with natural convection -40 +85 °C -40 +85 °C Climate class 3K3, 5 95% no condensation
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions ambient temperature • during operation — Note • during transport • during storage Humidity class according to EN 60721 Mechanics Connection technology Connections • Supply input	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable EN 61000-6-2 -25 +70 °C with natural convection -40 +85 °C -40 +85 °C Climate class 3K3, 5 95% no condensation screw-type terminals L, N: 1 screw terminal each for 0.5 2.5 mm2 single-core/finely stranded
UL/cUL (CSA) approval Explosion protection certificate of suitability NEC Class 2 FM approval CB approval certificate of suitability EAC approval certificate of suitability EAC approval Marine approval EMC Emitted interference Supply harmonics limitation Noise immunity environmental conditions ambient temperature • during operation — Note • during transport • during storage Humidity class according to EN 60721 Mechanics Connection technology Connections	cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) ATEX (EX) II 3G Ex nA IIC T3; cULus Class I Div. 2 (ANSI/ISA- 12.12.01, CSA C22.2 No. 213) Group ABCD, T4, File E488866 Yes Class I, Div. 2, Group ABCD, T4 Yes Yes ABS, BV, DNV GL, LRS EN 55022 Class B not applicable EN 61000-6-2 -25 +70 °C with natural convection -40 +85 °C -40 +85 °C Climate class 3K3, 5 95% no condensation

18 mm
90 mm
53 mm
20 mm
20 mm
0 mm
0 mm
0.07 kg
Yes
Snaps onto DIN rail EN 60715 35x7.5/15, direct mounting in different mounting positions
4 415 040 h
Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)

C