6GK5204-2AA00-2YF2

Data sheet



SCALANCE XF204-2BA DNA managed IE Y-switch, IEC 62443-4-2 certified; 4 x 10/100 Mbps, 2 x BusAdapter interface, error signaling contact, set button, redundant 24 V DC power supply, PROFINET device, extended temperature range -40 °C...+70 °C, conformal coating, with electr. manual on DVD, C-plug optional, supplied without BusAdapter

| product type designation | SCALANCE XF204-2BA DNA | |
|--|---|--|
| product options | XF-200 base device without mounted BusAdapter | |
| transfer rate | | |
| transfer rate | 10 Mbit/s, 100 Mbit/s | |
| interfaces / for communication / integrated | | |
| number of electrical connections | | |
| for network components or terminal equipment | 0 | |
| interfaces / other | | |
| number of electrical connections | | |
| for signaling contact | 1 | |
| • for power supply | 1 | |
| type of electrical connection | | |
| for signaling contact | 2-pole terminal block | |
| for power supply | 2-pole terminal block | |
| design of the removable storage | | |
| • C-PLUG | Yes | |
| signal inputs/outputs | | |
| operating voltage / of the signaling contacts | | |
| at DC / rated value | 24 V | |
| operational current / of the signaling contacts | | |
| at DC / maximum | 0.1 A | |
| supply voltage, current consumption, power loss | | |
| product component / connection for redundant voltage supply | Yes | |
| type of voltage / 1 / of the supply voltage | DC | |
| supply voltage / 1 / rated value | 24 V | |
| power loss [W] / 1 / rated value | 8.6 W | |
| supply voltage / 1 / rated value | 19.2 28.8 V | |
| consumed current / 1 / maximum | 0.36 A | |
| type of electrical connection / 1 / for power supply | 2-pole terminal block | |
| product component / 1 / fusing at power supply input | Yes | |
| ambient conditions | | |
| ambient temperature | | |
| during operation | -40 +70 °C | |
| during storage | -40 +85 °C | |
| during transport | -40 +85 °C | |
| relative humidity | | |

| • at 25 °C / without condensation / during operation / | 95 % |
|--|---|
| maximum | IDOO |
| protection class IP | IP20 |
| design, dimensions and weights | |
| design | compact |
| width | 100 mm |
| height | 117 mm |
| depth | 74 mm |
| net weight | 0.25 kg |
| fastening method | |
| 35 mm top hat DIN rail mounting | Yes |
| wall mounting | No |
| S7-300 rail mounting | No |
| S7-1500 rail mounting | No |
| product features, product functions, product components | / general |
| cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s | 50 |
| cascading in cases of star topology | any (depending only on signal propagation time) |
| product functions / management, configuration, engineering | ng |
| product function | |
| • CLI | Yes |
| web-based management | Yes |
| MIB support | Yes |
| TRAPs via email | Yes |
| configuration with STEP 7 | Yes |
| • port mirroring | Yes |
| multiport mirroring | Yes |
| PROFINET IO diagnosis | Yes |
| PROFINET conformity class | В |
| network load class / acc. to PROFINET | 2 |
| product function / switch-managed | Yes |
| protocol / is supported | |
| • Telnet | Yes |
| • HTTP | Yes |
| • HTTPS | Yes |
| • TFTP | Yes |
| • FTP | No |
| • BOOTP | No |
| • DCP | Yes |
| • LLDP | Yes |
| SNMP v1 | Yes |
| • SNMP v2 | Yes |
| SNMP v3 | Yes |
| identification & maintenance function | 165 |
| I&M0 - device-specific information | Yes |
| · | Yes |
| • I&M1 – higher level designation/location designation | 165 |
| product functions / diagnostics | |
| product function | Vee |
| port diagnostics this Parket Circ | Yes |
| statistics Packet Size | Yes |
| statistics packet type | Yes |
| error statistics | Yes |
| product functions / DHCP | |
| product function | |
| DHCP client | Yes |
| product functions / redundancy | |
| product function | |
| of the PROFINET IO device / is supported / | Yes |

| PROFINET system redundancy | |
|---|---|
| • ring redundancy | Yes |
| High Speed Redundancy Protocol (HRP) | Yes |
| high speed redundancy protocol (HRP) with | Yes |
| redundancy manager | |
| high speed redundancy protocol (HRP) with standby redundancy | Yes |
| protocol / is supported / Media Redundancy Protocol (MRP) | Yes |
| product function | |
| media redundancy protocol (MRP) with redundancy manager | Yes |
| Media Redundancy Protocol for Planned Duplication (MRPD) | No |
| of the PROFINET IO device / is supported / H-Sync forwarding | Yes |
| Parallel Redundancy Protocol (PRP)/operation in the PRP-network | No |
| Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA) | No |
| passive listening | Yes |
| product functions / security | |
| protocol / is supported | |
| • SSH | Yes |
| product functions / time | |
| product function | |
| SICLOCK support | No |
| protocol / is supported | |
| • NTP | No |
| • SNTP | Yes |
| system modification during operation | |
| System mounication during operation | |
| product function / configuration in RUN via CiR/H-CiR | Yes |
| | Yes |
| product function / configuration in RUN via CiR/H-CiR | Yes |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals | Yes FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes Tents EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environmental standard / for hazardous zone | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environn standard / for hazardous zone • from CSA and UL | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environments of the standard / for hazardous zone • from CSA and UL certificate of suitability | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environmental standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environs standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes Ten 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environs standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes EN 61000-6-2, EN 61000-6-4 |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environmental standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes EN 61000-6-2, EN 61000-6-4 Yes |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environmental standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes EN 61000-6-2, EN 61000-6-4 Yes Yes |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environed standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes Tents EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes EN 61000-6-2, EN 61000-6-4 Yes Yes No No |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environed standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • CCT / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes Tents EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes EN 61000-6-2, EN 61000-6-4 Yes Yes No No |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environment standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes Tents EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes EN 61000-6-2, EN 61000-6-4 Yes Yes No No |
| product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification Marine classification association | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 UL 61010-2-201 EN 61000-6-4:2001 (Class A) EN 61000-6-2, EN 61000-6-4 Yes Yes EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes EN 61000-6-2, EN 61000-6-4 Yes Yes No No No |

| accessories | |
|---|---|
| product extension / optional / C-PLUG | Yes |
| further information / internet-Links | |
| Internet-Link | |
| to web page: selection aid TIA Selection Tool | http://www.siemens.com/tia-selection-tool |
| to website: Industrial communication | http://www.siemens.com/simatic-net |
| to website: Industry Mall | https://mall.industry.siemens.com |
| to website: Information and Download Center | http://www.siemens.com/industry/infocenter |
| to website: Image database | http://automation.siemens.com/bilddb |
| to website: CAx-Download-Manager | http://www.siemens.com/cax |
| to website: Industry Online Support | https://support.industry.siemens.com |
| security information | |
| security information | Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4) |

last modified: 7/1/2021 🖸