**Data sheet** 

## 6GK5204-2AA00-2GF2



SCALANCE XF204-2BA managed IE switch, 4 x 10/100 Mbps, IEC 62443-4-2 certified; 2 x BusAdapter interface, error signaling contact, set button, redundant 24 V DC power supply, PROFINET device, extended temperature range -40  $^{\circ}$ C...+70  $^{\circ}$ C, conformal coating, with electr. manual on DVD, C-plug optional, supplied without BusAdapter

product type designation	SCALANCE XF204-2BA
product options	XF-200 base device without mounted BusAdapter
transfer rate	
transfer rate	10 Mbit/s, 100 Mbit/s
interfaces / for communication / integrated	
number of electrical connections	
<ul> <li>for network components or terminal equipment</li> </ul>	0
interfaces / other	
number of electrical connections	
<ul> <li>for signaling contact</li> </ul>	1
<ul><li>for power supply</li></ul>	1
type of electrical connection	
<ul> <li>for signaling contact</li> </ul>	2-pole terminal block
<ul><li>for power supply</li></ul>	2-pole terminal block
design of the removable storage	
• C-PLUG	Yes
signal inputs/outputs	
operating voltage / of the signaling contacts	
at DC / rated value	24 V
operational current / of the signaling contacts	
at DC / maximum	0.1 A
supply voltage, current consumption, power loss	
product component / connection for redundant voltage supply	Yes
type of voltage / 1 / of the supply voltage	DC
<ul><li>supply voltage / 1 / rated value</li></ul>	24 V
<ul><li>power loss [W] / 1 / rated value</li></ul>	8.6 W
<ul><li>supply voltage / 1 / rated value</li></ul>	19.2 28.8 V
<ul><li>consumed current / 1 / maximum</li></ul>	0.36 A
<ul> <li>type of electrical connection / 1 / for power supply</li> </ul>	2-pole terminal block
<ul> <li>product component / 1 / fusing at power supply input</li> </ul>	Yes
ambient conditions	
ambient temperature	
<ul> <li>during operation</li> </ul>	-40 +70 °C
<ul> <li>during storage</li> </ul>	-40 +85 °C
during transport	-40 +85 °C
relative humidity	

• at 25 °C / without condensation / during operation /	95 %	
maximum	IDOO	
protection class IP	IP20	
design, dimensions and weights		
design	compact	
width	100 mm	
height	117 mm	
depth	74 mm	
net weight	0.25 kg	
fastening method		
<ul> <li>35 mm top hat DIN rail mounting</li> </ul>	Yes	
<ul><li>wall mounting</li></ul>	No	
<ul> <li>S7-300 rail mounting</li> </ul>	No	
S7-1500 rail mounting	No	
product features, product functions, product components	/ general	
cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s	50	
cascading in cases of star topology	any (depending only on signal propagation time)	
product functions / management, configuration, engineering	ng	
product function		
• CLI	Yes	
<ul> <li>web-based management</li> </ul>	Yes	
MIB support	Yes	
TRAPs via email	Yes	
<ul><li>configuration with STEP 7</li></ul>	Yes	
• port mirroring	Yes	
multiport mirroring	Yes	
PROFINET IO diagnosis	Yes	
PROFINET conformity class	В	
network load class / acc. to PROFINET	2	
product function / switch-managed	Yes	
protocol / is supported		
• Telnet	Yes	
• HTTP	Yes	
• HTTPS	Yes	
• TFTP	Yes	
• FTP	No	
• BOOTP	No	
• DCP	Yes	
• LLDP	Yes	
SNMP v1	Yes	
• SNMP v2	Yes	
SNMP v3	Yes	
identification & maintenance function	165	
I&M0 - device-specific information	Yes	
·	Yes	
• I&M1 – higher level designation/location designation	165	
product functions / diagnostics		
product function	Ven	
port diagnostics     this Parket Circ	Yes	
statistics Packet Size	Yes	
statistics packet type	Yes	
error statistics	Yes	
product functions / DHCP		
product function		
DHCP client	Yes	
product functions / redundancy		
product function		
<ul><li>of the PROFINET IO device / is supported /</li></ul>	Yes	

PROFINET system redundancy	
	Yes
ring redundancy     High Speed Redundancy Protected (URB)	
High Speed Redundancy Protocol (HRP)  high speed as discrete as a control of the second	Yes
<ul> <li>high speed redundancy protocol (HRP) with redundancy manager</li> </ul>	Yes
high speed redundancy protocol (HRP) with standby redundancy	Yes
protocol / is supported / Media Redundancy Protocol (MRP)	Yes
product function	
<ul> <li>media redundancy protocol (MRP) with redundancy manager</li> </ul>	Yes
<ul> <li>Media Redundancy Protocol Interconnection (MRP-I)</li> </ul>	Yes
<ul> <li>Media Redundancy Protocol for Planned Duplication (MRPD)</li> </ul>	No
<ul> <li>of the PROFINET IO device / is supported / H-Sync forwarding</li> </ul>	Yes
<ul><li>redundancy procedure RSTP+</li></ul>	Yes
<ul> <li>Parallel Redundancy Protocol (PRP)/operation in the PRP-network</li> </ul>	No
<ul> <li>Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA)</li> </ul>	No
passive listening	Yes
product functions / security	
protocol / is supported	
• SSH	Yes
product functions / time	
product function	
<ul> <li>SICLOCK support</li> </ul>	No
protocol / is supported	
• NTP	No
• SNTP	Yes
SNTP system modification during operation	Yes
	Yes Yes
system modification during operation	
system modification during operation product function / configuration in RUN via CiR/H-CiR	
system modification during operation product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals	
system modification during operation product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM • for safety / from CSA and UL	Yes FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP.
system modification during operation  product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)
system modification during operation  product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference  • for interference immunity	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201
system modification during operation  product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference  • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)
system modification during operation  product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference  • for interference immunity  IT security for industrial automation systems / according to	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4
system modification during operation  product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference  • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4
system modification during operation  product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference  • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019  standards, specifications, approvals / CE	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes
system modification during operation  product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference  • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019  standards, specifications, approvals / CE  certificate of suitability / CE marking	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes
system modification during operation product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM  • for safety / from CSA and UL • for emitted interference • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes  Yes  Tents  EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07
system modification during operation product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM  • for safety / from CSA and UL • for emitted interference • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environn standard / for hazardous zone • from CSA and UL  certificate of suitability	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes  Yes  Ten 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A,
system modification during operation  product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference  • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019  standards, specifications, approvals / CE  certificate of suitability / CE marking  standards, specifications, approvals / hazardous environn standard / for hazardous zone  • from CSA and UL	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes  Yes  Ten 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A,
system modification during operation product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM  • for safety / from CSA and UL • for emitted interference • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environn standard / for hazardous zone • from CSA and UL  certificate of suitability	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes  Yes  Ten 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07  ATEX 0145X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
system modification during operation product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM  • for safety / from CSA and UL • for emitted interference • for interference immunity IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes  Yes  Ten 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07  ATEX 0145X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
system modification during operation product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM  • for safety / from CSA and UL • for emitted interference • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes  Yes  Tes  Yes  EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07  ATEX 0145X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes
system modification during operation  product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference  • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019  standards, specifications, approvals / CE  certificate of suitability / CE marking  standards, specifications, approvals / hazardous environe standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes  Yes  Ten 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  EN 61000-6-2, EN 61000-6-4
system modification during operation product function / configuration in RUN via CiR/H-CiR standards, specifications, approvals standard • for FM  • for safety / from CSA and UL • for emitted interference • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019  standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environn standard / for hazardous zone • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes  Yes  PN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  EN 61000-6-2, EN 61000-6-4  Yes
product function / configuration in RUN via CiR/H-CiR  standards, specifications, approvals  standard  • for FM  • for safety / from CSA and UL  • for emitted interference  • for interference immunity  IT security for industrial automation systems / according to IEC 62443-4-2:2019  standards, specifications, approvals / CE  certificate of suitability / CE marking  standards, specifications, approvals / hazardous environe standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  • C-Tick  • KC approval	Yes  FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4  UL 61010-2-201  EN 61000-6-4:2001 (Class A)  EN 61000-6-2, EN 61000-6-4  Yes  Yes  EN 60079-0: 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  EN 61000-6-2, EN 61000-6-4  Yes  Yes

Marine classification association	
<ul> <li>French marine classification society (BV)</li> </ul>	Yes
<ul> <li>Korean Register of Shipping (KRS)</li> </ul>	Yes
accessories	
product extension / optional / C-PLUG	Yes
further information / internet-Links	
Internet-Link	
<ul> <li>to web page: selection aid TIA Selection Tool</li> </ul>	http://www.siemens.com/tia-selection-tool
<ul> <li>to website: Industrial communication</li> </ul>	http://www.siemens.com/simatic-net
<ul><li>to website: Industry Mall</li></ul>	https://mall.industry.siemens.com
<ul> <li>to website: Information and Download Center</li> </ul>	http://www.siemens.com/industry/infocenter
<ul><li>to website: Image database</li></ul>	http://automation.siemens.com/bilddb
<ul><li>to website: CAx-Download-Manager</li></ul>	http://www.siemens.com/cax
<ul> <li>to website: Industry Online Support</li> </ul>	https://support.industry.siemens.com
security information	
security information	Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

7/1/2021