6GK5200-4AH00-2BA3

## **Data sheet**



SCALANCE X200-4PIRT managed IE IRT switch, 4x 100 Mbit/s POF SC RJ ports, Error signaling contact with set button, Redundant power supply, PROFINET IO device, network management, Redundancy Manager integrated, incl. electron. manual on CD-ROM, C-plug optional

product type designation	SCALANCE X200-4P IRT
transfer rate	
transfer rate	10 Mbit/s, 100 Mbit/s
interfaces / for communication / integrated	
number of 100 Mbit/s SC-RJ-ports / for POF FOC	
with push-pull connection system	4
interfaces / other	
number of electrical connections	
for signaling contact	1
<ul><li>for power supply</li></ul>	1
type of electrical connection	
<ul> <li>for signaling contact</li> </ul>	2-pole terminal block
<ul><li>for power supply</li></ul>	4-pole terminal block
design of the removable storage	
• C-PLUG	Yes
signal inputs/outputs	
operating voltage / of the signaling contacts	
at DC / rated value	24 V
operational current / of the signaling contacts	
<ul><li>at DC / maximum</li></ul>	0.1 A
supply voltage, current consumption, power loss	
type of voltage / 1 / of the supply voltage	DC
<ul><li>supply voltage / 1 / rated value</li></ul>	24 V
<ul><li>power loss [W] / 1 / rated value</li></ul>	9.6 W
<ul><li>supply voltage / 1 / rated value</li></ul>	18 32 V
<ul><li>consumed current / 1 / maximum</li></ul>	0.4 A
<ul> <li>type of electrical connection / 1 / for power supply</li> </ul>	4-pole terminal block
<ul> <li>product component / 1 / fusing at power supply input</li> </ul>	Yes
ambient conditions	
ambient temperature	
<ul> <li>during operation</li> </ul>	-25 +40 °C
<ul> <li>during storage</li> </ul>	-40 +70 °C
during transport	-40 +70 °C
relative humidity	
at 25 °C / without condensation / during operation / maximum	95 %
protection class IP	IP30

design, dimensions and weights	
design	compact
width	60 mm
height	125 mm
depth	124 mm
net weight	0.78 kg
	0.76 kg
fastening method	Voc
35 mm top hat DIN rail mounting	Yes
wall mounting	Yes
• S7-300 rail mounting	Yes
S7-1500 rail mounting	No
product features, product functions, product components	
cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s	50
cascading in cases of star topology	any (depending only on signal propagation time)
product functions / management, configuration, engineeri	ng
product function	
• CLI	Yes
web-based management	Yes
MIB support	Yes
TRAPs via email	Yes
• configuration with STEP 7	Yes
• port mirroring	No
-	No
<ul><li>multiport mirroring</li><li>with IRT / PROFINET IO switch</li></ul>	Yes
	Yes
PROFINET IO diagnosis	
PROFINET conformity class	C
network load class / acc. to PROFINET	2
product function / switch-managed	Yes
protocol / is supported	
• Telnet	Yes
• HTTP	Yes
HTTPS	Yes
• TFTP	Yes
• FTP	Yes
• BOOTP	No
• DCP	Yes
• LLDP	Yes
• SNMP v1	Yes
• SNMP v2	Yes
• SNMP v3	Yes
identification & maintenance function	
I&M0 - device-specific information	Yes
I&M1 – higher level designation/location designation	Yes
product functions / diagnostics	
product function	Voc
port diagnostics	Yes
statistics Packet Size	Yes
statistics packet type	Yes
error statistics	Yes
product functions / DHCP	
product function	
DHCP client	Yes
product functions / redundancy	
product function	
• ring redundancy	Yes
High Speed Redundancy Protocol (HRP)	Yes
<ul> <li>high speed redundancy protocol (HRP) with</li> </ul>	Yes

redundancy manager	
<ul> <li>high speed redundancy protocol (HRP) with standby redundancy</li> </ul>	Yes
protocol / is supported / Media Redundancy Protocol	Yes
(MRP)	165
product function	
<ul> <li>media redundancy protocol (MRP) with redundancy</li> </ul>	Yes
manager	
<ul> <li>Media Redundancy Protocol for Planned Duplication (MRPD)</li> </ul>	Yes
<ul> <li>Parallel Redundancy Protocol (PRP)/operation in the PRP-network</li> </ul>	Yes
<ul> <li>Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA)</li> </ul>	No
passive listening	Yes
product functions / security	
protocol / is supported	
• SSH	Yes
product functions / time	
product function	Vaa
SICLOCK support	Yes
protocol / is supported	
• NTP	No
• SNTP	Yes
standards, specifications, approvals	
standard	
• for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4
<ul> <li>for safety / from CSA and UL</li> </ul>	UL 60950-1, CSA C22.2 No. 60950-1
for emitted interference	EN 61000-6-4:2001
<ul> <li>for interference immunity</li> </ul>	EN 61000-6-2:2001
MTBF	73.06 y
standards, specifications, approvals / CE	
certificate of suitability / CE marking	Yes
standards, specifications, approvals / hazardous environr	**
standard / for hazardous zone	
Standard / for flazardous zone	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X
• from CSA and UL	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
certificate of suitability	1 - 1 - 1
CELLIFICATE OF SURADIIITA	
,	Yes
CCC / for hazardous zone according to GB standard	Yes
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other	
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability	EN 61000-6-2:2001, EN 61000-6-4:2001
<ul> <li>CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability</li> <li>C-Tick</li> </ul>	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability     C-Tick     KC approval	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability     C-Tick     KC approval     railway application in accordance with EN 50155	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1  accessories	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1 accessories  product extension / optional / C-PLUG	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability     C-Tick     KC approval     railway application in accordance with EN 50155     railway application in accordance with EN 50124-1 accessories     product extension / optional / C-PLUG further information / internet-Links	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1 accessories  product extension / optional / C-PLUG	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability     C-Tick     KC approval     railway application in accordance with EN 50155     railway application in accordance with EN 50124-1 accessories     product extension / optional / C-PLUG further information / internet-Links	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1 accessories  product extension / optional / C-PLUG  further information / internet-Links  Internet-Link	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1 accessories  product extension / optional / C-PLUG further information / internet-Links  Internet-Link  to web page: selection aid TIA Selection Tool	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No  Yes  http://www.siemens.com/tia-selection-tool
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1  accessories  product extension / optional / C-PLUG  further information / internet-Links  Internet-Link  to web page: selection aid TIA Selection Tool  to website: Industrial communication	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No  Yes  http://www.siemens.com/tia-selection-tool http://www.siemens.com/simatic-net
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1 accessories  product extension / optional / C-PLUG further information / internet-Links  Internet-Link  to web page: selection aid TIA Selection Tool  to website: Industrial communication  to website: Industry Mall	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No  Yes  http://www.siemens.com/tia-selection-tool http://www.siemens.com/simatic-net https://mall.industry.siemens.com
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No  Yes  http://www.siemens.com/tia-selection-tool http://www.siemens.com/simatic-net https://mall.industry.siemens.com http://www.siemens.com/industry/infocenter
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1  accessories  product extension / optional / C-PLUG  further information / internet-Links  Internet-Link  to web page: selection aid TIA Selection Tool  to website: Industrial communication  to website: Industry Mall  to website: Information and Download Center  to website: Image database  to website: CAx-Download-Manager	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No  Http://www.siemens.com/tia-selection-tool http://www.siemens.com/simatic-net https://mall.industry.siemens.com http://www.siemens.com/industry/infocenter http://automation.siemens.com/bilddb
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other  certificate of suitability  C-Tick  KC approval  railway application in accordance with EN 50155  railway application in accordance with EN 50124-1  accessories  product extension / optional / C-PLUG  further information / internet-Links  Internet-Link  to web page: selection aid TIA Selection Tool  to website: Industrial communication  to website: Industry Mall  to website: Information and Download Center  to website: Image database	EN 61000-6-2:2001, EN 61000-6-4:2001 Yes Yes No No  Yes  http://www.siemens.com/tia-selection-tool http://www.siemens.com/simatic-net https://mall.industry.siemens.com http://www.siemens.com/industry/infocenter http://automation.siemens.com/bilddb http://www.siemens.com/cax

security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

7/1/2021