

product description




Preset for PROFINET mode!

SCALANCE XB213-3 managed layer 2 IE switch 13x 10/100 Mbps RJ45 ports, 3x MM FO SC port 1x console port, diagnostics LED, redundant power supply, IEC 62443-4-2 certified; temperature range 0 °C to +60 °C; mounting onto standard rail; default PROFINET

| | |
|--|--|
| product type designation | SCALANCE XB213-3 |
| transfer rate | |
| transfer rate | 10 Mbit/s, 100 Mbit/s |
| interfaces / for communication / integrated | |
| number of electrical connections • for network components or terminal equipment | 13; RJ45 |
| number of 100 Mbit/s SC ports • for multimode | 3 |
| interfaces / other | |
| number of electrical connections • for operator console • for management purposes • for power supply | 1 1 1 |
| type of electrical connection • for operator console • for management purposes • for power supply | RJ11 RJ45 6-pole terminal block |
| supply voltage, current consumption, power loss | |
| product component / connection for redundant voltage supply | Yes |
| type of voltage / 1 / of the supply voltage • supply voltage / 1 / rated value • power loss [W] / 1 / rated value • supply voltage / 1 / rated value • consumed current / 1 / maximum • type of electrical connection / 1 / for power supply • product component / 1 / fusing at power supply input | DC 24 V 9.8 W 19.2 ... 28.8 V 0.41 A 6-pole terminal block Yes |
| ambient conditions | |
| ambient temperature • during operation • during storage • during transport | 0 ... 60 °C -40 ... +70 °C -40 ... +70 °C |
| relative humidity • at 25 °C / without condensation / during operation / maximum | 95 % |
| protection class IP | IP20 |

| design, dimensions and weights | |
|---|---|
| design | Box |
| width | 120 mm |
| height | 117 mm |
| depth | 109 mm |
| net weight | 0.5 kg |
| material / of the enclosure | Plastic |
| fastening method | |
| • 35 mm top hat DIN rail mounting | Yes |
| • wall mounting | No |
| • S7-300 rail mounting | No |
| • S7-1500 rail mounting | No |
| product features, product functions, product components / general | |
| cascading in the case of a redundant ring / at reconfiguration time of $\sim 0.3\text{ s}$ | 50 |
| cascading in cases of star topology | any (depending only on signal propagation time) |
| product functions / management, configuration, engineering | |
| product function | |
| • CLI | Yes |
| • web-based management | Yes |
| • MIB support | Yes |
| • TRAPs via email | Yes |
| • configuration with STEP 7 | Yes |
| • RMON | Yes |
| • port mirroring | Yes |
| • multiport mirroring | No |
| • CoS | Yes |
| • with IRT / PROFINET IO switch | No |
| • PROFINET IO diagnosis | Yes |
| PROFINET conformity class | B |
| product function / switch-managed | Yes |
| telegram length / for Ethernet / maximum | 1522 byte |
| protocol / is supported | |
| • Telnet | Yes |
| • HTTP | Yes |
| • HTTPS | Yes |
| • TFTP | Yes |
| • FTP | Yes |
| • BOOTP | No |
| • DCP | Yes |
| • LLDP | Yes |
| • EtherNet/IP | Yes |
| • SNMP v1 | Yes |
| • SNMP v2 | Yes |
| • SNMP v3 | Yes |
| • IGMP (snooping/querier) | Yes |
| identification & maintenance function | |
| • I&M0 - device-specific information | Yes |
| • I&M1 – higher level designation/location designation | Yes |
| product functions / diagnostics | |
| product function | |
| • port diagnostics | Yes |
| • statistics Packet Size | Yes |
| • statistics packet type | Yes |
| • error statistics | Yes |
| • SysLog | Yes |
| • loopback diagnostics | Yes |
| product functions / VLAN | |

| | |
|---|--|
| product function | |
| • VLAN - port based | Yes |
| • VLAN - protocol-based | No |
| • VLAN - IP-based | No |
| • VLAN dynamic | No |
| product functions / DHCP | |
| product function | |
| • DHCP client | Yes |
| product functions / redundancy | |
| product function | |
| • ring redundancy | Yes |
| • High Speed Redundancy Protocol (HRP) | Yes |
| • high speed redundancy protocol (HRP) with redundancy manager | Yes |
| • high speed redundancy protocol (HRP) with standby redundancy | Yes |
| protocol / is supported / Media Redundancy Protocol (MRP) | Yes |
| product function | |
| • media redundancy protocol (MRP) with redundancy manager | Yes |
| • redundancy procedure STP | Yes |
| • redundancy procedure RSTP | Yes |
| • redundancy procedure RSTP+ | Yes |
| • redundancy procedure MSTP | No |
| • Parallel Redundancy Protocol (PRP)/operation in the PRP-network | Yes |
| • Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA) | No |
| • passive listening | Yes |
| product functions / security | |
| product function | |
| • IEEE 802.1x (radius) | Yes |
| • broadcast/multicast/unicast limiter | Yes |
| • broadcast blocking | Yes |
| protocol / is supported | |
| • SSH | Yes |
| product functions / time | |
| product function | |
| • SICLOCK support | Yes |
| protocol / is supported | |
| • NTP | Yes |
| • SNTP | Yes |
| standards, specifications, approvals | |
| standard | |
| • for FM | FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4 |
| • for safety / from CSA and UL | UL 60950-1, CSA C22.2 No. 60950-1 |
| • for emitted interference | EN 61000-6-4 (Class A) |
| • for interference immunity | EN 61000-6-2 |
| IT security for industrial automation systems / according to IEC 62443-4-2:2019 | Yes |
| standards, specifications, approvals / CE | |
| certificate of suitability / CE marking | Yes |
| standards, specifications, approvals / hazardous environments | |
| standard / for hazardous zone | EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X |
| • from CSA and UL | ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T9 |
| certificate of suitability | |

| | |
|---|---|
| <ul style="list-style-type: none"> • CCC / for hazardous zone according to GB standard | Yes |
| standards, specifications, approvals / other | |
| certificate of suitability | EN 61000-6-2, EN 61000-6-4 |
| <ul style="list-style-type: none"> • C-Tick | Yes |
| <ul style="list-style-type: none"> • KC approval | Yes |
| <ul style="list-style-type: none"> • railway application in accordance with EN 50155 | No |
| <ul style="list-style-type: none"> • railway application in accordance with EN 50124-1 | No |
| further information / internet-Links | |
| Internet-Link | |
| <ul style="list-style-type: none"> • to web page: selection aid TIA Selection Tool | http://www.siemens.com/tia-selection-tool |
| <ul style="list-style-type: none"> • to website: Industrial communication | http://www.siemens.com/simatic-net |
| <ul style="list-style-type: none"> • to website: Industry Mall | https://mall.industry.siemens.com |
| <ul style="list-style-type: none"> • to website: Information and Download Center | http://www.siemens.com/industry/infocenter |
| <ul style="list-style-type: none"> • to website: Image database | http://automation.siemens.com/bilddb |
| <ul style="list-style-type: none"> • to website: CAx-Download-Manager | http://www.siemens.com/cax |
| <ul style="list-style-type: none"> • to website: Industry Online Support | https://support.industry.siemens.com |
| security information | |
| security information | Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity . To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com . (V3.4) |
| last modified: | 7/1/2021  |