SIEMENS

Data sheet

6GK5206-2GS00-2TC2



SCALANCE XC206-2SFP G (E/IP) managed Layer 2 IE switch; IEC 62443-4-2 certified; 6x 10/100/1000 Mbps RJ45 ports; 2x 1000 Mbps SFP; 1x console port; diagnostics LED; redundant power supply; temp. range -40 °C to +70 °C; mounting: DIN rail/S7 mounting rail/wall; redundancy functions; Office features (RSTP, VLAN,...); PROFINET IO device; Ethernet/IP-compliant; C-plug slot; Default EtherNet/IP

Figure similar

product type designation	SCALANCE XC206-2SFP G (E/IP def.)
transfer rate	
transfer rate	10 Mbit/s, 100 Mbit/s, 1000 Mbit/s
interfaces / for communication / integrated	
number of electrical connections	
 for network components or terminal equipment 	6; RJ45
number of 10/100/1000 Mbit/s RJ45 ports / integrated	
with securing collar	6
interfaces / for communication / plug-in	
number of electrical connections	
• for SFP	2
interfaces / other	
number of electrical connections	
 for operator console 	1
 for signaling contact 	1
for power supply	1
type of electrical connection	
 for operator console 	RJ11
for signaling contact	2-pole terminal block
for power supply	4-pole terminal block
design of the removable storage	
• C-PLUG	Yes
signal inputs/outputs	
operating voltage / of the signaling contacts	
at DC / rated value	24 V
operational current / of the signaling contacts	
at DC / maximum	0.1 A
supply voltage, current consumption, power loss	
product component / connection for redundant voltage supply	Yes
type of voltage / 1 / of the supply voltage	DC
supply voltage / 1 / rated value	24 V
power loss [W] / 1 / rated value	6 W
 consumed current / 1 / at rated supply voltage / maximum 	0.25 A
supply voltage / 1 / rated value	9.6 31.2 V
consumed current / 1 / maximum	0.5 A

 type of electrical connection / 1 / for power supply 	4-pole terminal block
 product component / 1 / fusing at power supply input 	Yes
ambient conditions	
ambient temperature	
during operation	-40 +70 °C
during storage	-40 +85 °C
during transport	-40 +85 °C
relative humidity	
 at 25 °C / without condensation / during operation / 	95 %
maximum	ID00
protection class IP	IP20
design, dimensions and weights	
design	compact
width	60 mm
height	147 mm
depth	125 mm
net weight	0.52 kg
material / of the enclosure	Polycarbonate (PC-GF10) / pressure die cast aluminum
fastening method	
 35 mm top hat DIN rail mounting 	Yes
wall mounting	Yes
S7-300 rail mounting	Yes
S7-1500 rail mounting	Yes
product features, product functions, product components	/ general
cascading in the case of a redundant ring / at	50
reconfiguration time of <\~0.3\~s	
cascading in cases of star topology	any (depending only on signal propagation time)
product function / QoS according to DSCP	Yes
product feature	
Cut Through switching method	No
Store & Forward switching method	Yes
product functions / management, configuration, engineering	ng
product function	
• CLI	Yes
 web-based management 	Yes
 MIB support 	Yes
TRAPs via email	Yes
configuration with STEP 7	Yes
• RMON	Yes
SMTP server	No
 port mirroring 	Yes
 multiport mirroring 	Yes
• CoS	Yes
PROFINET IO diagnosis	Yes
PROFINET conformity class	В
network load class / acc. to PROFINET	3
product function / switch-managed	Yes
telegram length / for Ethernet / maximum	10240 byte
protocol / is supported	
Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• BOOTP	No
• GMRP	Yes
• DCP	Yes
• LLDP	Yes
EtherNet/IP	Yes

• SNMP v1 Yes	
• SNMP v2 Yes	
• SNMP v3 Yes	
• IGMP (snooping/querier) Yes	
identification & maintenance function	
• I&M0 - device-specific information Yes	
• I&M1 – higher level designation/location designation Yes	
product functions / diagnostics	
product function	
• port diagnostics Yes	
• statistics Packet Size Yes	
• statistics packet type Yes	
• error statistics Yes	
• SysLog Yes	
product functions / VLAN	
product function	
VLAN - port based Yes	
VLAN - protocol-based No	
• VLAN - IP-based No	
number of VLANs / maximum 257	
number of VLANs - dynamic / maximum 257	
protocol / is supported / GVRP Yes	
product functions / DHCP	
product function	
• DHCP server Yes	
• DHCP client Yes	
• DHCP Option 82 Yes	
• DHCP Option 66 Yes	
DHCP Option 67 Yes	
product functions / redundancy	
product function	
 of the PROFINET IO device / is supported / PROFINET system redundancy 	
• ring redundancy Yes	
 High Speed Redundancy Protocol (HRP) Yes	
 high speed redundancy protocol (HRP) with redundancy manager 	
 high speed redundancy protocol (HRP) with standby redundancy 	
protocol / is supported / Media Redundancy Protocol Yes (MRP)	
product function	
 media redundancy protocol (MRP) with redundancy manager 	
Media Redundancy Protocol Interconnection (MRP- I) Yes	
 of the PROFINET IO device / is supported / H-Sync forwarding 	
• of the PROFINET IO device / is supported / H-Sync Yes	
• of the PROFINET IO device / is supported / H-Sync forwarding	
 of the PROFINET IO device / is supported / H-Sync forwarding redundancy procedure STP Yes	
 of the PROFINET IO device / is supported / H-Sync forwarding redundancy procedure STP redundancy procedure RSTP Yes Yes 	
 of the PROFINET IO device / is supported / H-Sync forwarding redundancy procedure STP redundancy procedure RSTP redundancy procedure RSTP+ 	
 of the PROFINET IO device / is supported / H-Sync forwarding redundancy procedure STP redundancy procedure RSTP redundancy procedure RSTP+ redundancy procedure RSTP+ Yes redundancy procedure MSTP Parallel Redundancy Protocol (PRP)/operation in 	
of the PROFINET IO device / is supported / H-Sync forwarding redundancy procedure STP redundancy procedure RSTP redundancy procedure RSTP+ redundancy procedure MSTP Parallel Redundancy Protocol (PRP)/operation in the PRP-network Parallel Redundancy Protocol (PRP)/Redundant No	
of the PROFINET IO device / is supported / H-Sync forwarding redundancy procedure STP redundancy procedure RSTP redundancy procedure RSTP+ redundancy procedure RSTP+ redundancy procedure MSTP Parallel Redundancy Protocol (PRP)/operation in the PRP-network Parallel Redundancy Protocol (PRP)/Redundant Notework Access (RNA)	
of the PROFINET IO device / is supported / H-Sync forwarding redundancy procedure STP redundancy procedure RSTP redundancy procedure RSTP+ redundancy procedure MSTP redundancy procedure MSTP Parallel Redundancy Protocol (PRP)/operation in the PRP-network Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA) passive listening	

product function	
• IEEE 802.1x (radius)	Yes
 broadcast/multicast/unicast limiter 	Yes
broadcast blocking	Yes
protocol / is supported	
• SSH	Yes
• SSL	Yes
product functions / time	
product function	
 SICLOCK support 	Yes
NTP-client	Yes
SNTP client	Yes
protocol / is supported	
• NTP	Yes
• SNTP	Yes
system modification during operation	
product function / configuration in RUN via CiR/H-CiR	Yes
standards, specifications, approvals	
IT security for industrial automation systems / according to	Yes
IEC 62443-4-2:2019	165
MTBF	55 y
standards, specifications, approvals / CE	
certificate of suitability / CE marking	Yes
product conformity / according to EMC-guideline	2014/30/EU
standard	2014/30/20
for EMC interference emission	EN 61000-6-4, EN 50121-7
• for immunity to EMC	EN 61000-6-2, EN 50121-4
certificate of suitability / RoHS conformity	Yes; 2011/65/EU
standards, specifications, approvals / hazardous environn	nents
certificate of suitability	V FN 00070 0 FN 00070 45
• ATEX	Yes; EN 60079-0, EN 60079-15
• for ATEX / as marking	II 3 G Ex nA II T4 Gc
• for ATEX / as certificate	KEMA 07ATEX0145 X
for ATEX / as certificateIECEx	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15
 for ATEX / as certificate IECEx for IECEx / as marking 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005,
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEX DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C
for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C
for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as marking railway applications, approvals / other certificate of suitability railway application in accordance with EN 50121-4	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEX DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X
for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes
for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability railway application in accordance with EN 50121-4 Regulatory Compliance Mark (RCM)	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes Yes E85972 (NRAQ, NRAQ7)
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability railway application in accordance with EN 50121-4 Regulatory Compliance Mark (RCM) for UL 61010-2-201 / as File Nr. for UL 60950-1 / as File Nr. 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes E85972 (NRAQ, NRAQ7) E115352 (NWGQ, NWGQ7)
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability railway application in accordance with EN 50121-4 Regulatory Compliance Mark (RCM) for UL 61010-2-201 / as File Nr. for UL 60950-1 / as File Nr. EAC approval 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes Yes E85972 (NRAQ, NRAQ7)
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability railway application in accordance with EN 50121-4 Regulatory Compliance Mark (RCM) for UL 61010-2-201 / as File Nr. for UL 60950-1 / as File Nr. EAC approval 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes E85972 (NRAQ, NRAQ7) E115352 (NWGQ, NWGQ7) Yes
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability railway application in accordance with EN 50121-4 Regulatory Compliance Mark (RCM) for UL 61010-2-201 / as File Nr. for UL 60950-1 / as File Nr. EAC approval accessories product extension / optional / C-PLUG 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEX DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes E85972 (NRAQ, NRAQ7) E115352 (NWGQ, NWGQ7)
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability railway application in accordance with EN 50121-4 Regulatory Compliance Mark (RCM) for UL 61010-2-201 / as File Nr. for UL 60950-1 / as File Nr. EAC approval accessories product extension / optional / C-PLUG further information / internet-Links 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes E85972 (NRAQ, NRAQ7) E115352 (NWGQ, NWGQ7) Yes
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability railway application in accordance with EN 50121-4 Regulatory Compliance Mark (RCM) for UL 61010-2-201 / as File Nr. for UL 60950-1 / as File Nr. EAC approval accessories product extension / optional / C-PLUG further information / internet-Links Internet-Link 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes Yes Yes Yes Yes Yes Yes Yes
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability railway application in accordance with EN 50121-4 Regulatory Compliance Mark (RCM) for UL 61010-2-201 / as File Nr. for UL 60950-1 / as File Nr. EAC approval accessories product extension / optional / C-PLUG further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEX DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes Yes E85972 (NRAQ, NRAQ7) E115352 (NWGQ, NWGQ7) Yes http://www.siemens.com/fia-selection-tool
 for ATEX / as certificate IECEx for IECEx / as marking for IECEx / as certificate CCC / for hazardous zone according to GB standard for cULus HazLoc / as marking for cULus HazLoc / as File Nr. FM registration for FM / as marking for FM / as certificate standards, specifications, approvals / other certificate of suitability railway application in accordance with EN 50121-4 Regulatory Compliance Mark (RCM) for UL 61010-2-201 / as File Nr. for UL 60950-1 / as File Nr. EAC approval accessories product extension / optional / C-PLUG further information / internet-Links Internet-Link 	KEMA 07ATEX0145 X Yes; IEC 60079-0, IEC 60079-15 Ex nA II T4 Gc IECEx DEK 14.0025X Yes CL1, DIV2, Group A,B,C,D T4, CL1, Zone 2, Group IIC, T4 E240480 (NWHP, NWHP7) Yes; FM class 3600:2011, FM class 3611:2004, FM class 3810:2005, ANSI/ISA-61010-1:2004 CL1, DIV2, group A,B,C,D T4, CL1, Zone 2, group IIC, T4 Ta: -40 °C +70 °C FM16US0205X Yes Yes Yes Yes Yes Yes Yes Yes Yes

• to website: Information and Download Center

• to website: Image database

to website: CAx-Download-Managerto website: Industry Online Support

http://www.siemens.com/industry/infocenter http://automation.siemens.com/bilddb

http://www.siemens.com/cax

https://support.industry.siemens.com

security information

security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

7/1/2021